



COMMONWEALTH of VIRGINIA

B. Cameron Webb, MD, JD
State Health Commissioner

DEPARTMENT OF HEALTH
**OFFICE OF DRINKING
WATER**
Richmond Field Office

Madison Building
109 Governor St., 6th floor
Richmond, VA 23219
Phone: 804-864-7409
Fax: 804-864-7520

System Sanitary Survey Report

May 15, 2026

To: Anthony Westmoreland
Dollar General - Louisa
108 Lake Drive
Clayton, NC, 27520

SUBJECT: Louisa County
Waterworks: Dollar General - Louisa
PWSID: VA2109210

Survey Date: April 24, 2026

Next Survey Due By: April 24, 2031

Present at Survey:

Name	Organization
Lydia Belser	Virginia Department of Health- Office of Drinking Water
Lyndsey Mccauley	Virginia Department of Health- Office of Drinking Water
Chase Westmoreland	Stormwater Operations Specialists, LLC

Reviewer: Toby Bryant

As a result of the sanitary survey noted above, the Office of Drinking Water offers the following comments. Should you have questions or desire to discuss our findings, please contact us at 804-910-6111 or Lydia.Belser@vdh.virginia.gov.

ACCOLADES:

We would like to offer the following accolades to recognize exceptional performance at your waterworks:

SIGNIFICANT DEFICIENCIES:

There were no significant deficiencies at the time of this inspection.

MINOR DEFICIENCIES:

The Virginia Waterworks Regulations require your waterworks to complete the following actions. Failure to complete these actions by the specified dates may result in a Notice of Alleged Violation.

Section	Recommendations
Distribution System	Our office does not have record of all cross connections or the most recent required annual testing of backflow prevention devices. Please provide a record the the annual testing to our office by August 31, 2026.
Distribution System	The most current Cross Connection Control Program was approved on 6/2/2020 and is not in line with current regulations. Complete the Cross Connection Control Plan (CCCP) for your waterworks found at this web address(https://www.vdh.virginia.gov/drinking-water/cross-connection-control/). Send the completed document to our office by August 31, 2026.

RECOMMENDATIONS:

There were no recommendations at the time of this inspection.

Please review the attached summary of required sampling and visit our web site at <http://www.vdh.virginia.gov/ODW/>. There you will find helpful information on water sampling and testing, operator licensing and training, consumer education, project funding and **many other topics, as well as, links to other key websites and Virginia's *Waterworks Regulations*.**

Survey By:



Lydia Belser
Env Health Spec Sr

Attachments:

- a. Field Report
- b. Usage Report

Louisa County Health Department
Louisa County Administrator