



# COMMONWEALTH of VIRGINIA

B. Cameron Webb, MD, JD  
State Health Commissioner

DEPARTMENT OF HEALTH

## OFFICE OF DRINKING WATER

Richmond Field Office

Madison Building  
109 Governor St., 6<sup>th</sup> floor  
Richmond, VA 23219  
Phone: 804-864-7409  
Fax: 804-864-7520

### System Sanitary Survey Report

May 15, 2026

To: Anthony Westmoreland  
Dollar General- Mineral  
108 Lake Drive  
Clayton, NC, 27520

SUBJECT: Louisa County  
Waterworks: Dollar General- Mineral  
PWSID: VA2109215

Survey Date: April 24, 2026

Next Survey Due By: April 24, 2031

Present at Survey:

Name	Organization
Lydia Belser	Virginia Department of Health- Office of Drinking Water
Lyndsey Mccauley	Virginia Department of Health- Office of Drinking Water
Chase Westmoreland	Storm Water Operations, Llc

Reviewer: Toby Bryant

As a result of the sanitary survey noted above, the Office of Drinking Water offers the following comments. Should you have questions or desire to discuss our findings, please contact us at 804-910-6111 or Lydia.Belser@vdh.virginia.gov.

#### ACCOLADES:


We would like to offer the following accolades to recognize exceptional performance at your waterworks:

#### SIGNIFICANT DEFICIENCIES:

There were no significant deficiencies at the time of this inspection.

**MINOR DEFICIENCIES:**

The Virginia Waterworks Regulations require your waterworks to complete the following actions. Failure to complete these actions by the specified dates may result in a Notice of Alleged Violation.

<b>Section</b>	<b>Recommendations</b>
Well No. 1	The well lot needs maintenance, specifically mowing in order to easily reach the well. Please mow the well lot by December 31, 2026, to maintain easy access to the well head. 
Distribution System	Our office does not have record of all cross connections or the most recent required annual testing of backflow prevention devices. Please provide a record of the annual testing to our office by August 31, 2026.

**RECOMMENDATIONS:**

There were no recommendations at the time of this inspection.

Please review the attached summary of required sampling and visit our web site at <http://www.vdh.virginia.gov/ODW/>. There you will find helpful information on water sampling and testing, operator licensing and training, consumer education, project funding and **many other topics, as well as, links to other key websites and Virginia's *Waterworks Regulations*.**

Survey By:



Lydia Belser  
Env Health Spec Sr

Attachments:

- a. Field Report
- b. Usage Report